

CAVE BAY COMMUNITY SERVICES (CBCS), INC.
PO BOX 115
WORLEY ID 83876-0115

CONSTRUCTION INFORMATION AND AGREEMENT

Water and waste water hookup requirements:

1. Water line must have, in addition to the CBCS shutoff, a double check valve and a separate shutoff accessible outside the structure. A pressure regulator is highly recommended.
2. Waste water (sewer) line must have a check valve at the property line.
3. Septic tank must be dual chamber with a 1500 gallon capacity.
4. Life pump must be rated at least 1 hp. The Gould WE1012H and Little Giant 513520 230-volt pumps are examples of equipment meeting this standard.
5. You must obtain a permit from Panhandle Health will require a letter of permission to hook up to the CBCS systems before they will issue a permit. The permission letter may be obtained by contacting the CBCS bookkeeper at 208-686-7106 Home or 208-686-5161 Office.
6. Property owners must acknowledge receipt of this information and agreement, including information listed on the reverse of this page, in writing. A copy of this letter will be retained in the CBCS files and the original letter will be provided to the property owner.

I acknowledge receipt and understanding of the contents of this document. I understand I will be held liable for damage done by myself, my agent(s), or contractor(s) or other persons in my employ to any CBCS, Inc.-owned property, including roads. Failure to repair damage or compensate CBCS, Inc. for damage may result in the establishment of a lien on my property by CBCS, Inc.

Date

Signature of Property Owner