

Quanics

Engineering Water Solutions®

P.O. Box 1520
Crestwood, KY 40014
1-877-QUANICS
www.quanics.net

Installation Sheet

Pump Vault Float Tree

ATS-FT-2,3 or 4




STEP 1

Glue handle to top of handle assembly pipe. Place float wires through wire clips and reattach to clamp. Snap clamp back onto handle assembly. Adjust float heights to desired depth.



STEP 2

Slide float tree handle assembly and floats onto guide pipe attached to the filtered pump vault.



STEP 3

Proceed feeding float wires through junction box attached to riser. Leave plenty of wire so float tree can be removed without cutting wires. Loop excess wire and attach to riser wall just under the lid.

***Note: Tether lengths and float clamp heights can be adjusted after installation.**